



# TRIDENT

WATER TREATMENT

## CYCLO-MAX

### CLOSED LOOP SYSTEM TREATMENT

BORATE/NITRITE SCALE AND CORROSION INHIBITOR  
FOR USE IN BOTH HOT OR COLD WATER CLOSED LOOPS

#### DANGER

Harmful if swallowed. Causes severe skin burns and eye damage.  
May cause cancer. May damage fertility or the unborn child.

**KEEP OUT OF REACH OF CHILDREN**

NET CONTENTS:  1  5  20  35  55 Gallon(s)

# TRIDENT

WATER TREATMENT

## CYCLO-MAX



P.O. Box 245013  
Milwaukee, WI 53224

(800) 776-7192

www.sharecorp.com



#### DANGER:

Harmful if swallowed. Causes severe skin burns and eye damage. May cause cancer. May damage fertility or the unborn child.

#### PREVENTION:

Obtain special instructions before use. Do not handle until all safety precautions have been read and understood. Do not breathe spray, mist. Wash thoroughly after handling. Do not eat, drink or smoke when using this product. Wear eye protection, protective clothing, protective gloves. Wash contaminated clothing before reuse.

**IF SWALLOWED:** rinse mouth. Do NOT induce vomiting. Immediately call a doctor, a POISON CENTER.

**IF ON SKIN (OR HAIR):** Take off immediately all contaminated clothing. Rinse skin with water/shower.

**IF INHALED:** Remove person to fresh air and keep comfortable for breathing.

**IF IN EYES:** Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing.

**If exposed or concerned:** Get medical advice/attention.

Store locked up.

Dispose of contents/container to comply with local/regional/national/international regulations.

*For industrial and commercial use only.*

*For additional information, see Safety Data Sheet.*

**TRIDENT CYCLO-MAX** is a scale and corrosion inhibitor for hot water boiler recirculating systems and chilled water recirculating systems. **TRIDENT CYCLO-MAX** is a borate/nitrite formula for superior scale and corrosion inhibition, with easy testing and control.

#### DIRECTIONS:

The dosage of **TRIDENT CYCLO-MAX** will depend on the amount of water contained in the recirculating system. Normal treatment dosage is 1 gallon of **TRIDENT CYCLO-MAX** for every 125 gallons of water contained within the system. **TRIDENT CYCLO-MAX** may be injected directly into the recirculating system through the use of a regular bypass feeder. Mild steel piping and feeding equipment may be used. Control the level of **TRIDENT CYCLO-MAX** by maintaining a nitrite (NO<sub>2</sub>) level of between 350-1000ppm.

In chilled water recirculating systems, a microbicide is recommended as a preventative treatment or for control if infestation occurs. Many hot water and chilled water recirculating systems may require the use of an oxygen scavenger. Control oxygen scavenger feed rates by maintaining a sulfite (SO<sub>3</sub>) level of between 20-40 ppm.

**WARNING:** This product can expose you to formaldehyde, which is known to the State of California to cause cancer. For more information go to [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov).

#### NFPA® RATINGS:

Health: 2; Flammability: 0; Reactivity: 0

#### CONTAINS/CAS#:

Water (7732-18-5); Sodium nitrite (7632-00-0); Disodium tetraborate decahydrate (1303-96-4); Sodium hydroxide (1310-73-2); Dispersant (Proprietary).



Please Recycle.

1983.021521